SPWS NAME:

SPWS NO:

The tables below contain the chemical and physical monitoring that must be conducted for each of the source(s) in the . The Alpine County Health Department will review the data and establish the frequency for ongoing source monitoring. Your water system has been classified as a **Transient, non-community water systems (serves 25 people, 60 or more days per year)**

Parameter	Req'd frequency	Last analysis	Next analysis due
Bacteria	Monthly when operating	monthly	monthly
General Minerals (Iron, Manganese, Magnesium, Calcium, Sodium, Specific Conductance, µS/cm, pH, Hydroxide alkalinity, total hardness	once		
Nitrate	annually		
Nitrite	every 3 years		
Fluoride	once		